

SUBCONTRACTOR APPLICATION AND VERIFICATION FORM

TELEPHONE: 919-772-4698

FAX: 919-662-5135

YOU MAY USE THIS FORM FOR YOUR PERMIT APPLICATION OR TO VALIDATE YOUR LICENSE FOR A BUILDING PERMIT.

PERMIT#: 2090341 CONTRACT AMOUNT OR COST ESTIMATE: \$ 187,680

PROJECT ADDRESS: 4851 Jones Sausage Rd Garner, NC 27529

OWNER INFORMATION:

OWNER: Con Agra Foods Phone: 919.772.1511

ADDRESS: 4851 Jones Sausage Rd

CITY: Garner STATE: NC ZIP: 27529

* **SUB-CONTRACTOR INFORMATION:**

SUB-NAME: Southern Industrial Constructors, Inc.

ADDRESS: 6101 Triangle Drive

CITY: Raleigh STATE: NC ZIP: 27617

PHONE: 919-782-4600 STATE LICENSE#: 10149 Privilege License # 11115

**CITY OF RALEIGH UTILITY INFORMATION FOR TAPS AND BACKFLOW
FOR TAP INSPECTION CALL 919-250-2737**

UTILITY CONT: _____

ADDRESS: _____

CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ STATE LICENSE#: _____ Privilege License # _____

TAP INFORMATION:

WATER: SIZE: _____ SEWER: SIZE: _____

BACKFLOW INFORMATION:

DEVICE TYPE AND SIZE: _____ MANUFACTURER/MODEL: _____

* **WORK DESCRIPTION:**

PLEASE SUMMARIZE ALL WORK BELOW:

Cut in 6" x 6" T AND ADD A ball valve AND tie
in ^{into} ~~between~~ NATURAL GAS MAIN - ALSO ADD T+ valve to 4" x 4" 2 1/2"

UNDER PENALTY OF LAW, THE UNDERSIGNED DOES HEREBY CERTIFY, THAT THE SIGNATURE SHOWN IS THE SIGNATURE OF THE LICENSE HOLDER OR AN AUTHORIZED AGENT OF THE LICENSE HOLDER. THE UNDERSIGNED FURTHER INDEMNIFYS THE TOWN OF GARNER AND ITS EMPLOYEES AGAINST DAMAGES THAT MAY ARISE DURING THE CONSTRUCTION PROCESS.

Prop
L.W.

* H. Kendall McKeon / PERMIT MANAGER
SUBCONTRACTOR OR AUTHORIZED SIGNATURE

7/1/09
DATE:

Donald Rothman
UTILITY CONTRACTOR OR AUTHORIZED SIGNATURE

6/1/09
DATE:

TOWN OF GARNER INSPECTION REPORT
TEL 919-772-4688, FAX 919-662-5135

Total Re-Inspection Fees Due: \$0.00

Permit: 2090341

Issue Date: 5/29/2009

Business Name:

Owner's Name: CON AGRA SNACK FOODS

Owner's Phone #:

Type of Improvement: Plumbing

Proposed Use: GAS HOT WATER HEATER

Property Address: 4851 JONES SAUSAGE ROAD Lot #:

Subdivision:

Date Requested: 6/9/2009

Type: Gas Piping

Comments

CALLED IN BY JOHN ... READY AT 9:00 AM
 INSTALLING TWO WATER HEATERS

Electrical	FREEDOM ELECTRIC INC.	252-908-2268
Plumbing	SOUTHERN INDUSTRIAL CONSTRUCTORS	919-782-4600
Mechanical	SOUTHERN INDUSTRIAL CONSTRUCTORS	919-782-4600

INSPECTORS FINDINGS:

APPROVED 10 psi test only REJECTED _____ COND. APPROVAL _____

RE-INSP. FEE REQ. YES ___ NO 1 B ___ E ___ P ___ M 1 TOTAL FEE: \$ 0

INSPECTOR [Signature] DATE: 6-9-09

CORRECTIONS REQUIRED BEFORE PROCEEDING

10 psi on L.P. 0.14
need mech find
DOL inspection
plumbing find
regulator + fresh air info



TOWN OF GARNER INSPECTION REPORT
TEL 919-772-4688, FAX 919-662-5135

Total Re-Inspection Fees Due: \$0.00

Permit: 2090341

Issue Date: 5/29/2009

Business Name:

Owner's Name: CON AGRA SNACK FOODS

Owner's Phone #:

Type of Improvement: Plumbing

Proposed Use: GAS HOT WATER HEATER

Property Address: 4851 JONES SAUSAGE ROAD Lot #:

Subdivision:

Date Requested: 6/4/2009

Type: Gas Piping rough in

Comments

READY AT 1:00 PM. CALLED IN BY DON
 INSTALLING TWO WATER HEATERS.

Electrical	FREEDOM ELECTRIC INC.	252-908-2268
Plumbing	SOUTHERN INDUSTRIAL CONSTRUCTORS	919-782-4600
Mechanical	SOUTHERN INDUSTRIAL CONSTRUCTORS	919-782-4600

INSPECTORS FINDINGS:

APPROVED REJECTED _____ COND. APPROVAL _____

RE-INSP. FEE REQ. YES _____ NO B _____ E _____ P _____ M TOTAL FEE: \$ 0

INSPECTOR DLR DATE: 6-4-09

CORRECTIONS REQUIRED BEFORE PROCEEDING

O.K. to set meter

*gas test O.K., noticed
 gas to new water heater*



Online Register

Licensee Details



North Carolina
State Board of Examiners
of Plumbing, Heating and
Fire Sprinkler Contractors



[Home](#)

License No:	10149
License Expires On:	12/31/2009
Class(es):	P-1, H-1-1, H-2, H-3-1
Business:	Southern Industrial Constructors, Inc 6101 Triangle Dr Raleigh, NC 27617
Phone:	(919) 782-4600
Fax:	919-782-2935
By:	Edwards, Donald R (P-1, H-1-1, H-2, H-3-1)

Lookup another:

License number:

License Class:

County Name

Business name:

Personal name
(first, last):

City:

NC

Updated

May 11, 2009



[Home](#)



[SiteMap](#)



[Search](#)

Please report problems with this site to: webmaster@nclicensing.org

Copyright © 1998-1999 by the NC State Board of Examiners of
Plumbing, Heating and Fire Sprinkler Contractors

Town of Garner
P.O. BOX 446
Garner, NC 27529
TEL: 919-772-4688 FAX: 919-662-5135

Permit #: 2090341		Fee Paid: 150.00		Receipt#: 404234		Issue Date: 5/29/2009		
In Town: Yes	Zoning:	NCPIN:	Census Tract:	Flood Zone:	Panel Number:	Elevation:	Req. Elevation:	
Owner: CON AGRA SNACK FOODS		Owner's Phone:	Bus. Name:	Owner's Address: 4851 JONES SAUSAGE ROAD		City: GARNER	State: NC	Zip: 27529
Property Address: 4851 JONES SAUSAGE ROAD								
Subdivision::				Phase::		Lot #::		

Comments:
INSTALLING TWO WATER HEATERS

Heat:	Sewer:	Frame:	Water:	Type: C	Improvement Type: Plumbing	Use: GAS HOT WATER HEATER		Stories:	Sq Ft:	Beds:	Baths:
Manufacturer:		Model:	Color:	Width:	Year:	Length:	Serial Number:	HUD Number:			
Building Cost:		Electrical Cost:		Plumbing Cost		Mechanical Cost:		Other Costs:	Total Cost 187680		

Contractors:

Electrical BATTLEBORO	FREEDOM ELECTRIC INC. NC 27809	5268 N. BROWNTOWN ROAD 252-908-2268
Plumbing	NEED ON FILE	

THIS PERMIT BECOMES NULL AND VOID IF WORK OR CONSTRUCTION AUTHORIZED IS NOT COMMENCED WITHIN SIX(6) MONTHS, OR IF CONSTRUCTION IS SUSPENDED OR ABANDONED FOR A PERIOD OF 12 MONTHS AFTERWORK IS STARTED. NO WORK AUTHORIZED BY ANY PERMIT THAT HAS EXPIRED SHALL BE PERFORMED UNTIL A NEW PERMIT HAS BEEN SECURED.

IT IS UNDERSTOOD AND AGREED BY THE UNDERSIGNED OWNER OF AGENT THAT THE APPROVAL OF THIS PERMIT DOES NOT CONSTITUTE A PRIVILEGE TO VIOLATE THE STATE BUILDING CODE, ZONING ORDINANCE, OR OTHER ORDINANCES OF THE TOWN OF GARNER AND THAT ANY OMISSION OF OR MISREPRESENTATION OF FACT WITH OR WITHOUT INTENTION OF THE UNDERSIGNED, OR ANY ALTERATION OR CHANGE FROM THIS PERMIT WITHOUT WRITTEN APPROVAL OF THE INSPECTIONS DEPARTMENT, SHALL CONSTITUTE SUFFICIENT GROUNDS FOR THE REVOCATION OF THIS PERMIT. THE UNDERSIGNED FUTHER INDEMNIFYS THE TOWN OF GARNER AND ITS EMPLOYEES FROM DAMAGES THAT MAY ARISE DURING THE COURSE OF CONSTRUCTION.

Owner / Agent Signature David Potter DATE: 5/29/09



ConAgra Foods

4851 Jones Sausage Road

Garner, NC 27529

Subject: Fuel Line Sizing

John,

Based on the attached chart a 2000' - 6" steel fuel-line will deliver 26.9 million Btus at 5 psig delivery pressure of natural gas. And based on the attached chart a 2000' - 3" steel fuel-line will deliver 2.5 million Btus at 5 psig delivery pressure of natural gas. Your current delivery pressure is 5 psig and current load is 20 million Btus.

If you have further questions, please give me a call.

Sincerely,

Steven A. Rhodes

Large Account Representative

919-367-2704